

RFQ-2026-0702

Supply of Rosemount Instrument Transmitter for GPS2 Fuel Gas Control System

Bill of Quantities

1. The Bidder's price stated in this Bill of Quantities shall be on a firm price basis in **Singapore Dollars (SGD)** and shall be inclusive of DDP (Incoterms 2020) to BPC Store, Berakas Power Station, Brunei Darussalam.
2. Products manufactured in China or India are not acceptable. Only genuine Emerson Rosemount transmitters manufactured in Singapore, Malaysia, North America (USA/Canada), Japan or Europe shall be accepted. The supplier shall clearly state the country of origin for each item in the quotation and provide supporting documentation (e.g., Certificate of Origin or Manufacturer's Declaration) upon delivery.
3. Only new, unused and genuine Emerson Rosemount products shall be supplied. Refurbished, repaired or surplus items are not acceptable. Hence, the supplier shall provide a Manufacturer's Certificate of Conformance (CoC) certifying that the equipment supplied is new, genuine, unused, and conforms to the specified model numbers and manufacturer's specifications.
4. Each transmitter shall be supplied with a Manufacturer's Factory Calibration Certificate, traceable to national or international standards.
5. All transmitters shall be configured in accordance with the Purchaser's instrument datasheets and configuration sheets prior to shipment.
6. Only Emerson Rosemount transmitters same model (as stated in table below) are acceptable to ensure a like-for-like replacement with the existing installed instruments. Hence, alternative manufacturers **WILL NOT** be considered as they may result in additional site work modification for system recovery.
7. Payment terms is 30 days upon submission of original invoice after the goods are received at BPC Store.

Item	Description	Qty	Unit Rate	Amount
	Supply and delivery (Incoterms 2020: DDP Brunei Darussalam) inclusive of unloading of the following to BPC Store at Berakas Power Station, Brunei Darussalam:			
1.	Emerson Rosemount 3144P Temperature Transmitter Model: 3144PD2A2E1B4M5G1C4Q4HR7	2 Nos.		
2.	Emerson Rosemount 3051T Pressure Transmitter Model: 3051TG3A2B22BB4E8Y2Q4M5D0V5HR7	1 No.		
3.	Emerson Rosemount 3051C Differential Pressure (DP) Transmitter Model: 3051CD2A2B1BB4E8Y2L4Q4M5D0V5HR7	1 No.		
	Total Amount (SGD)			

Delivery Schedule (*Note: Bidder to state, assuming issuance of purchase order by 25th August 2026)

BPC Required Delivery	Guaranteed Delivery Date by the Bidder*
30 th October 2026	

(Signature and Company Stamp)

Date:

Name :

Company Name :

Address :

Telephone number: Fax No. :

E-mail address: